

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190730-R39009  
**Report Reference** R39009-20171207  
**Issue Date** 2019-JULY-30

**Issued to:** GIANNI INDUSTRIES INC  
13 ZHONG SING RD  
TU-CHENG INDUSTRIAL ZONE  
TU-CHENG DISTRICT  
NEW TAIPEI  
236 TAIWAN

**This certificate confirms that  
representative samples of**

ELECTRIC STRIKES  
Electric Strike, GK1270, GK1275, GK1276, GK1280 and  
GK1297 Series with optional suffix M, for use on fire doors  
and frames with ratings up to and including 1.5 h.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 10C - Standard for Positive Pressure Fire Tests of  
Door Assemblies  
CAN/ULC-S104, Standard Method for Fire Tests of Door  
Assemblies

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up  
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's  
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

