

CERTIFICATE OF COMPLIANCE

Certificate Number 20151120-R21198
Report Reference R21198-20030624
Issue Date 2015-NOVEMBER-20

Issued to: GIANNI INDUSTRIES INC
13 ZHONG SING RD, TU-CHENG INDUSTRIAL ZONE
TU-CHENG DISTRICT, NEW TAIPEI
236 TAIWAN

This is to certify that representative samples of Auxiliary locksets of the Electromagnet Type
See Addendum Page


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10B - Fire Tests of Door Assemblies.
ANSI/UL 10C - Positive Pressure Fire Tests of Door Assemblies.
CAN/ULC S104 - Standard Method for Fire Tests of Door Assemblies.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20151120-R21198
Report Reference R21198-20030624
Issue Date 2015-NOVEMBER-20


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models GL-600, GL-1200, N1001ST and N10010ST for use with swinging type fire door for use on swinging type fire doors rated up to and including 1-1/2 h. All devices may be provided with or without one or more of the following Suffixes: 12, 24, F, FS, IOTB, M, R, S

Models may have the following voltage options:

Models GL-1200 and N10010ST - 12 V dc, 24 V dc or combination 12/24 V dc unit with 1200 lb holding force,

Models GL-600 and N10001ST - dual voltage unit, 12/24 V dc with 600 lb holding force.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

