

CERTIFICATE OF COMPLIANCE

Certificate Number R39009
Report Reference R39009-20200515
Issue Date 2020-MAY-15

Issued to: GIANNI INDUSTRIES INC
13 ZHONG SING RD, TU-CHENG INDUSTRIAL ZONE, TU-CHENG DISTRICT, NEW TAIPEI, 236 TAIWAN

This certificate confirms that representative samples of

ELECTRIC STRIKES
USL - Electric Strike, GK360-ST, GK360M-ST, GK361-ST and GK361M-ST Series, with suffix -1224, for use on fire doors and frames with fire rated twenty minutes without hose stream

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI/UL 10B- Fire Tests of Door Assemblies
ANSI/UL 10C- Positive Pressure Fire Test of Door Assemblies

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

